



**County Engineer
Environmental Engineer
Building Department**
233 W. Sixth Street
Marysville, Ohio 43040
P 937. 645. 3018
F 937. 645. 3161
www.unioncountyohio.gov/engineer

Marysville Operations Facility
16400 County Home Road
Marysville, Ohio 43040
P 937. 645. 3017
F 937. 645. 3111

Richwood Outpost
190 Beatty Avenue
Richwood, Ohio 43344

Public Service with integrity

ADDENDUM #1

FROM: Union County Engineers Office
Josh Holtschulte

DATE: April 19, 2023

RE: **UNI-CR222D-3.57 Bridge Replacement**

PAGES: 2

This addendum supplements and amends the original Drawings and Specification issued and shall be taken into account in preparing proposals, and shall become a part of the Contract Documents.

1. *Reference Instructions to Bidders Number 16 (Time of Commencement, Completion and Milestone Dates) on page 4.4 of the bid documents:* Construction work shall be completed not later than October 31, 2023. The actual period of work shall not exceed ~~90 calendar days~~ **120 calendar days**.
2. *Reference Instructions to Bidders Number 18 (Documents Required at the Time of Proposal) on page 4.5 of the bid documents:* Certification of Non-Segregated Facilities is listed but was not included in the bid documents. Because this project is not federally funded this form is not required as part of the bid packet.
3. There is no DBE requirement.
4. Video inspection of conduit described in Item 611.12 will not be required.
5. Proposal Note 555 (smoothness measurements) will not be required.
6. Galvanized piles will not be allowed. Complete encasement of piles will be required as described in the plans.
7. Reference Proposal: Item 202 – PIPE REMOVED 24” & UNDER was in the plans but not in the original proposal. This has been added to the new proposal.
8. Reference Proposal: Item SPECIAL – PILE ENCASEMENT units changed from EA to FT
9. Reference Proposal: Item 516 – SEMI-INTEGRAL ABUTMENT EXPANSION JOINT SEAL units changed from SF to FT

10. Reference Proposal: Item 526 – REINFORCED CONCRETE APPROACH SLAB, AS PER PLAN (T=12”)(15’ LONG) units changed from CY to SY
11. A revised proposal is attached. A revised Excel spreadsheet proposal has also been placed on the Union County Engineer’s website at <https://www.unioncountyohio.gov/bid-info> as *Proposal (MS Excel) – revised 4/19/2023*.
12. The soil boring results are attached.

Please note and sign the bottom portion of 6.6 of the bid packet proposal acknowledging that this Addendum was received.